

CORREGENDUM-1 dtd 12-01-2012
TENDER ENQUIRY No. 77/11/6309/RSB

Item : Supply of cast basalt lined MSERW / SW pipes for AHP Sikka 2 x 250 MW TPS

(1) The due date for submission of tender is **extended upto 20-01-2012**

(2) Changes in pre-qualification requirements and technical specifications shall be as mentioned below:-

Sl. No.	Tender ref./ clause no.	KEY CHANGES	Original tender clause	Shall be now read as
1.	Clause no. 7: 1.2, Vol-1, Sec - 1	Deleted erection and commissioning from experience list.	Bidder should have designed, engineered, manufactured, supplied, <i>erected</i> , tested and <i>commissioned</i> minimum 1000 mtrs of CAST BASALT LINED MSERW PIPES for Ash Handling plant of thermal power stations for ash slurry conveying and these pipes should be in successful operation in India for a period of at least Two (2) years in the preceding 5 years on the date for submission of bid.	Bidder should have designed, engineered, manufactured, tested and supplied minimum 1000 mtrs of CAST BASALT LINED MSERW PIPES for Ash Handling plant of thermal power stations for ash slurry conveying and these pipes should be in successful operation in India for a period of at least Two (2) years in the preceding 5 years on the date for submission of bid.
2	Clause no. 7: 2.0, Vol-1, Sec - 1	Deleted erection and commissioning	Bidder shall provide documentary evidence in support of his claim for having experience in design, manufacture, supply, <i>erection</i> , testing and <i>commissioning</i> of cast basalt lined MS ERW pipes for Ash Handling Plants which are in operation on the date of submission of bid.	Bidder shall provide documentary evidence in support of his claim for having experience in design, manufacture, testing and supply of cast basalt lined MS ERW pipes for Ash Handling Plants which are in operation on the date of submission of bid.
3	Volume 2 Clause 2.0. f. i		Cast Basalt Fittings: Sleeve type coupling joint at an interval of approximately 40 meters in straight length.	Sleeve type coupling joint at an interval of approximately 36 meters in straight length.
4	Volume 2 Clause 2.0. f.iii And clause no. 5 c	Regarding shipping length of pipes and flanged connection	Flanged joints in pipe at every 12 mtrs.	Pipes shall be dispatched in standard length of 6000 ± 100 mm . Flanged connections at every shipping length. For flange details please refer the attached drawing.
5	---	---	The approximate quantity of flanges and sleeve coupling in total 1020 mtr length of each size of pipe are: i) No. of straight pipes of 6 mtrs length: 170 nos. ii) Sleeve couplings with hardware : 30 nos. iii) Flanges (as per attached drg) : 284 nos.	
6	Volume 2 Clause 2.0. 3.i	Casing MS ERW/ SW in place of MSERW.	Casing - MS ERW pipe of 373 mm OD conforming to IS 3589, 6.0 mm wall thickness.	Casing - MS ERW / SW pipes of 373 mm OD conforming to IS 3589, 6.0 mm wall thickness.